

LA STATE PLUMBING CODE REQUIREMENT FOR MOBILE HOMES TRAILER TRAP & VENT STACK

1003.3.2 Slip joints may be used on both sides of the trap and in the trap seal.

1003.3.3 A trap which is integral with the fixture shall have a uniform interior and a smooth waterway.

1003.4 Drum Traps

1003.4.1 Drum traps shall be limited to special fixtures designed for drum traps and are subject to approval by the plumbing official. They shall be not less than 4-inch diameter and shall have a water seal of not less than 2 inches (51 mm).

1003.4.2 The trap screw shall be one size less than the trap diameter.

1003.5 Trailer Traps

Mobile/manufactured homes and travel trailers shall be provided with a trailer trap in the building sewer/sewer lateral immediately downstream of the mobile/manufactured home or travel trailer drain outlet connection. The trailer trap shall be individually vented and the vent shall be located downstream of the trap at a distance in accord with Table 908.1. Running traps are prohibited for this installation. (See diagram under B112 or C112.)

EXCEPTION: The trailer trap for a mobile/manufactured home or travel trailer is not required to be provided with an individual vent if the mobile/manufactured home or travel trailer is connected to a park drainage system constructed in accord with B108.7 and the building sewer/sewer lateral is no longer than 30 feet (9144 mm) from the main park drainage sewer. (See B108.10 and C107.5.1)

TRAILER TRAP AND VENT


APPROVED MATERIALS FOR TRAP AND VENT

- (1) CAST IRON PIPE AND FITTINGS.
- (2) ABS OR PVC PLASTIC PIPE AND FITTINGS SCH. 40
(NOTE: DO NOT MIX ABS AND PVC PIPE AND/OR FITTINGS.)

APPROVED SEWER PIPES:

- (1) CAST IRON SEWER PIPE
- (2) VITRIFIED CLAY SEWER PIPE
- (3) APPROVED PLASTIC PIPE AND FITTINGS (MIN. SDR 35 OR HEAVIER)
(NOTE: FROM A POINT AT LEAST 3 FEET OUTSIDE THE EDGE OF THE TRAILER TO SEWAGE SYSTEM.)

NOTE: D-2729 NOT APPROVED FOR ANY PART OF SYSTEM



**THIS IS REQUIRED AND WILL BE INSPECTED
ON ALL MOBILE HOME PERMITS**